



CSI TESTING

14020 23rd Avenue N., Plymouth, MN 55447

(763) 383-9535 • Facsimile (763) 383-9546

Clean Environment Testing Since 1975

CERTIFICATE OF COMPLIANCE

**Colder Products
1001 Westgate Drive
St. Paul, Minnesota 55114**

December 7 & 14, 2007

| Clean Area Description | Clean Area Class | Clean Area Status |
|------------------------|------------------|-------------------|
| Cleanroom | 10,000 / ISO 7 | Operational |
| Controlled Zone | 100,000 / ISO 8 | Operational |
| Staging Room | 10,000 / ISO 7 | At-Rest |
| Wipe Down Room | 10,000 / ISO 7 | At-Rest |
| Gown Room | 10,000 / ISO 7 | At-Rest |
| 670 / 770 Machine | 10,000 / ISO 7 | At-Rest |

Per the results of the particle count testing, the class is considered met if the measured particle concentration is within the limits specified per Federal Standard 209E, page 5, table 1, as determined by the statistical analysis of pages 14 and 15, paragraphs 5.4.2 through 5.4.2.6 and ISO 14644-1 (1999). Particle counts were sampled and reported in the cumulative mode for sizes 0.5 µm, 1.0 µm, and 5.0 µm at a flow rate of 1 cubic foot per minute.

CSI Testing, Inc. certifies that the above referenced clean area has been tested and meets or exceeds the stated class conditions in accordance with Federal Standard 209E and ISO 14644-1 (1999). CSI Testing, Inc. makes no other warranties, stated or implied, concerning the continued performance, operation or safety in use of the clean spaces listed above.

Submitted and Certified by:
CSI Testing, Inc.

Carl LaBella
President